Date:	20/11/2024
Facility:	Dubbo Regional Organics Processing Plant (DROPP)
EPL:	20998
Entity:	J.R. & E.G. Richards (NSW) Pty Ltd
	Cooba Rd, Dubbo, NSW 2830
	1 Nov 2023 to 31 Oct 2024
Monitoring Point:	Point 1 - Stormwater Discharge
	Stormwater Discharge and Quality
Requirement:	EPL 20998 - P1.2, L2.4, M2.2

SUMMARY		Discharge Monitoring									
Month-Year	Were there any discharges?	Oil & Grease			рН			TSS			Comments
		Measured	Limit	Exceedance?	Measured	Limit	Exceedance?	Measured	Limit	Exceedance?	
Nov-23	No discharge										
Dec-23	No discharge										
Jan-24	No discharge										
Feb-24	No discharge										
Mar-24	No discharge										
Apr-24	Discharge on 5/4/2024	6.3mg/L	10mg/L	No	7.98	6.5 - 8.5	No	31mg/L	50mg/L	No	
May-24	No discharge										
Jun-24	No discharge										
Jul-24	No discharge										
Aug-24	No discharge										
Sep-24	No discharge										
Oct-24	No discharge										